
DESCRIPTION ULTIMATE STRENGTH ITEM NO. PART NUMBER QTY. MATERIAL ASH-66-BC **ANCHOR SHACKLE** 2 FORGED STEEL 60,000 LBS. 2 LOO-50-15 OVAL EYE/OVAL EYE 2 FORGED STEEL 50,000 LBS. 3 SYCR-56 2 90° SOCKET Y-CLEVIS **DUCTILE IRON** 30,000 LBS. Y2VS050S1845 TRIANGULAR TANGENT YOKE STEEL 50,000 LBS. 4 5 CF SUSPENSION CLAMP ALUMINUM 25,000 LBS.

Y-CLEVIS INSULATOR

PAPER	SIZE	DRAWING NUMBER		
	В	X3VS2YB30B2		
REV	DATE	DESCRIPTION	REV	ВҮ



NOTE: INSULATORS AND **CONDUCTOR KIT SOLD SEPARATELY**

ASSEMBLY CAT. NO. X3VS2YB30B2

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN: **INCHES** TOLERANCES ARE: X +/- 0.1 +/- 0.03 .XX .XXX +/- 0.015 ANGLES +/- 1.0

COMPOSITE

WWW.MACLEANPOWER.COM

DRAWING NUMBER: DO NOT SCALE DRAWING CAD GENERATED DRAWING DO NOT MANUALLY UPDATE SHEET1 DRAWING DESCRIPTION

V-STRING

ASSEMBLY

DESIGN DATE: 3/25/24 DRAWN BY: JIP

ENGINEER: APPROVED:

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 11411 Addison Street, Franklin Park, Illinois 60131, USA."

6

D

DRAWING SCALE: 1:1